

RAJGARH NEEMUCH POWER TRANSMISSION LIMITED
NOTICE
(Under sub-section (2) of Section 15 of the Electricity Act, 2003)

1. RAJGARH NEEMUCH POWER TRANSMISSION LIMITED, having its Registered Office at CORE-4, SCOPE COMPLEX, 7, LODHI ROAD, DELHI, SOUTH DELHI, DELHI, INDIA, 110003, which is incorporated under the Companies Act, 2013, has made an application before the Central Electricity Regulatory Commission, New Delhi under sub-section (1) of Section 15 of the Electricity Act, 2003 for grant of transmission license in respect of the transmission lines, sub-stations and other assets, the details of which are given:

Sl. No.	Name of the line/Sub- station (location)	Line length/ Capacity	Estimated Completion Cost or levelized Transmission Charges	Commissioning Schedule	Remarks
1.	Creation of New 220 kV Bus Section (3rd) with 220 kV Bus Sectionaliser and 400/220 kV, 3x500 MVA ICT augmentation (7th, 8th & 9th) at Pachora PS terminated on 220 kV Bus Section (3rd)	400/220 kV	Rs. 367.073 Crore	29.09.2027	
2	2a. 3 Nos. 220 kV line bays for RE interconnection on Bus Section (3rd)	220 kV			
	2b. 1 No. 220 kV line bay for RE Interconnection of Purvah Green Power Pvt. Ltd. on Bus Section (3rd)	220 kV			
3	Pachora PS – Rajgarh(PG) 400 kV D/c line (Quad ACSR/ AAAC/ AL59 Moose equivalent) along with associated line bays at both ends and 50 MVAR (Sw LR) on each ckt at both ends	185.448 Km			
4	Installation of 1x125 MVAR, 420 kV bus reactor at Pachora PS (400 kV Bus Section-II)	125 MVAR			
5	Creation of New 220 kV Bus Section-II at Neemuch PS with Augmentation of transformation capacity by 3x500 MVA, 400/220 kV ICTs (3rd, 4th and 5th) at Neemuch S/s along with associated bays.	400/220 kV			
6	4 Nos. 220 kV Line bays at Neemuch PS for RE interconnection	220 kV			
7	Neemuch PS – Pachora PS 400 kV D/c line (Quad ACSR/ AAAC/ AL59 Moose equivalent) along associated Line	220.99 Km			

	bays and 50 MVAR Switchable Line Reactor (Sw LR) on each ckt at both ends				
8	Establishment of 2x500 MVA, 400/220 kV S/s at Handiya alongwith 2x125 MVAR 420 kV Bus Reactors	400/220 kV			
9	Pachora PS – Handiya 400 kV D/c line (Quad ACSR/ AAAC/ AL59 Moose equivalent) along with associated bays at Pachora PS end and 50 MVAR Switchable Line Reactor (Sw LR) on each ckt at both ends	214.43 Km			
10	LILO of Khandwa(PG) – Itarsi (PG) 400 kV D/c (Twin Moose) line at Handiya S/s	Line In – 15.346 Km & Line Out – 14.291 Km			
11	Installation of 1x125 MVAR, 420 kV bus reactor (2nd) at Neemuch PS	125 MVAR			

2. Complete application and other documents filed before the Commission are available on the website www.grinfra.com. The application can also be inspected at the office of the Company at 2nd Floor, Novus Tower Plot No. 18, Sector-18 Gurugram, Haryana-122015 with Mr. Afak Pothiawala or Office of the Commission in accordance with the procedure specified by the Commission.
3. Objections or suggestions, if any, be filed before **the Secretary, Central Electricity Regulatory Commission, 6th, 7th & 8th Floors, Tower B, World Trade Centre, Nauroji Nagar, New Delhi – 110029**, with a copy of the objection(s)/suggestion(s) to the applicant or its authorized agent, within 15 days of the publication of the notice.

Place: Gurugram
Date: 07.10.2025

Afak Pothiawala
Authorised signatory